



Declaration of conformity

| For the following equipment | : | | |
|--|--|---|---|
| Product Name: Switching Po | ower Supply | | |
| Model Designation: ERPF-400-x (x=12,24,48) | | | |
| is herewith confirmed to con applied: | nply with the requirements | set out in the Council Direc | ctive, the following standards were |
| RoHS Directive (2011/6 | 65/EU) · (EU)2015/863 | | |
| Low Voltage Directive (2 | 014/35/EU) : | | |
| EN 62368-1:2014+A11 | | TUV certificate No : R50471613 | |
| Electromagnetic Compa EMI (Electro-Magnetic II Conducted emission / Radia | nterference) | · | s A |
| Harmonic current | EN IEC 61000-3-2:2019 | 9+A1:2021 | |
| Voltage flicker | EN 61000-3-3:2013+A1 | :2019 | |
| EMS (Electro-Magnetic Susceptibility) | | | |
| EN 55035:2017+A11:2020 | | | |
| ESD air | EN 61000-4-2:2009 | Level 3 | 8KV |
| ESD contact | EN 61000-4-2:2009 | Level 2 | 4KV |
| RF field susceptibility | EN IEC 61000-4-3:2020 | Level 2 | 3V/m |
| EFT bursts | EN 61000-4-4:2012 | Level 2 | 1KV/5KHz |
| Surge susceptibility | EN 61000-4-5:2014+A1 | :2017 Level 3 | 1KV/Line-Line |
| Surge susceptibility | EN 61000-4-5:2014+A1 | :2017 Level 3 | 2KV/Line-Earth |
| Conducted susceptibility | EN 61000-4-6:2014 | Level 2 | 3V |
| Magnetic field immunity Voltage dip, interruption | EN 61000-4-8:2010 EN IEC 61000-4-11:2020 periods | Level 2 >95% dip 0.5 periods 30% | 3A/m dip 25 periods >95% interruptions 250 |
| Note: Component power supply will be operated with a final equipment. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again. Tests above are only to be performed with resistive loads. For guidance on how to perform these EMC tests, please refer to TDF (Technical Documentation File). | | | |
| This Declaration is effective from | m serial number GC1xxxxxxx | | |
| Person responsible for mark | ing this declaration: | | |
| MEAN WELL Enterprises Co (Manufacturer Name) | o., Ltd. | | |
| No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 24891, Taiwan | | | |
| (Manufacturer Address) | Anta | = .=. | |
| Aries Jian/ Director, Group R&D: (Name / Position) | (Signature) | Alex Tsai/Director, Product Stra (Name / Position) | (Signature) |
| Taiwan | Oct. 28th, 2021 | | |
| (Place) | (Date) | | |